



**PAPIRUS**

Public Administration Procurement Innovation  
to Reach Ultimate Sustainability



The research leading to these results has received funding from the European Union  
CIP Entrepreneurship and Innovation Programme under grant agreement n° SI2.662792.



## PAPIRUS

– open procedure –

### Questions regarding the tender documents

<b>Contracting authority:</b>		
<b>The Municipal Undertaking for Social Service Buildings of Oslo (Omsorgsbygg Oslo KF)</b>		
<b>Oslo, Norway</b>		
<b>Submission date</b>	<b>Question</b>	<b>Answer</b>
24.04.2015	With reference to annex 1 technical specifications point 4.3.1: Does the estimated area of 3350m2 include windows?	The estimated area of 3350m2 does not include windows.
24.04.2015	Tender document point 4: Does the estimate value for lot 1 include external and inner cladding?	The estimated maximum contract value of € 402 000 for lot 1 is for a complete wall including external and inner cladding.
24.04.2015	Has the material for the outer cladding been decided?	No, this has not yet been decided.
24.04.2015	With reference to annex 1 technical specifications point 4.4.3 Particular requirements:  Does the minimum requirement: "have a fire resistance of at least EI60" apply to all windows?	We have discovered an error in the specification.  The requirement that windows must "have a fire resistance of at least EI60" is removed from the specification, see annex 1 technical specifications point 4.4.3 Particular requirements.  There are no requirements regarding fire resistance for windows.